

Buildings: Residential: Single Family

Team members: Veronica Crothers and Karl Telleen (Maffei Structural Engineering); Betsy Mathieson, and Simpson Strongtie Team

Observations afternoon 8/25/2014

Area Surveyed:

Jefferson Street from EERI Clearinghouse (Pueblo Ave) to Fuller Park (near Downtown/Laurel Street)

Observations:

- Northern portion of Jefferson Street (around EERI Clearinghouse) is mostly 1-story strip malls. Did not observe damage from car, so did not stop to look carefully.
- Southern portion of Jefferson Street (closer to downtown) is more residential and/or large single-family homes used as commercial. Observed:
 - approximately four (4) chimney partial collapses
 - two (2) cripple wall failures
 - one (1) unstable canopy (appendage to building) out-of-plumb
 - Safeway closed, yellow-tagged, merchandise toppled and ceiling damage
 - Napa High School includes several concrete buildings; no damage observed from our brief walk around campus.